

**Blower Replacement Kits on
AquaTemp Units, H137W-"C" Series and CO151W-"B" Series Models:
Kit Nos. 0769-180-01-ALK, 0769-180-01-SSK (120 Volts)
0769-182-01-ALK, 0769-182-01-SSK (240 Volts)**

1. Cut tie wraps holding motor wires
2. Remove motor wires from terminal block
3. Remove the two screws holding motor housing to unit. (See ITEM 1)
4. Lift motor blower out of unit. (See ITEM 2)
5. Set new motor blower in being careful to match the tabs for the screws
6. Install and tighten screws
7. Attach motor wires to terminal block
8. Attach tie wraps to wires to keep away from motor

